

## TECHNICAL DATASHEET

### Introduction:

**FireHalt 120:30** is a **BRE/LPCB Certified** lightweight symmetrical fire barrier designed to provide compartmentation in roof cavities and concealed spaces as detailed in *UK Building Regulations: Approved Document B (Fire Safety)*.

**Firehalt 120:30** is simple to fit and requires no specialist tools or fittings.

### Physical Properties:

Description:	Non-toxic / User friendly / flexible / durable Easy to manipulate and cut to shape
Colour:	Green
Coating:	Weavelock treatment including a proprietary fire resistant additive which is food safe and non-corrosive.
Minimum Thickness:	7 mm
Minimum Weight:	1900 g/m <sup>2</sup>
Fibre Diameter	> 6 micron, (classified non-respirable)

### Test Specification:

**BS 476: parts 20/22 120 minutes integrity  
30 minutes insulation**

Satisfies the requirements of *UK Building Regulations: Approved Document B (Fire Safety)* for fire rated cavity barriers.

### Certification Body:

**LPCB Certified Cavity Barrier Ref # 552a/02**

### Test & Assessment Authority:

Exova Warringtonfire	Horizontal Assessment	Ref # 179691
	Movement joint Assessment	Ref # 176621
	Pipe Protection Assessment	Ref # 178495
	Timber Protection Assessment	Ref # 179691
	BS 476 part 6: 1989 Class O (Fire propagation)	
	BS 476 part 7: 1987 Class 1 (Surface spread of flame)	
	ISO 1182 1990 (E): Non Combustibility	
	IMO Resolution MSC.61(67) Part 1. Non Combustibility	

### Packing & Dimensions:

Width:	130cm	Packed: Convoluted and individually wrapped in polythene.
Roll Length:	6m Standard	
Roll Area:	7.8m <sup>2</sup>	



Culimeta-Saveguard Ltd,  
+44 (0)161 344 2484  
sales@saveguard.com  
www.culimeta-saveguard.com



The information on this Data Sheet is provided in good faith. However, the company reserves the right to alter or update this data as and when additional information is received. Firehalt products should only be fitted in accordance with the guidelines provided by the manufacturer. Any deviations must be authorised by the manufacturer or their representatives.

Issue No:	1	Page:	1 of 1	Dated:	1 April 2017	File Ref:	Prodata firehalt 120_30 130cm	.pdf
-----------	---	-------	--------	--------	--------------	-----------	-------------------------------	------