



#	DESCRIPTION	NOTES
1	FIREHALT BARRIER	
2	BRUSHSEAL PACKING	Brushseal folded & packed to generously fill the web of "I" section
3	BRUSHSEAL WRAP	3 Wraps
4	300mm BARRIER OVER-SLEEVE	Wrapped around the Brushseal & beam - joined with a 50mm stapled joint
5	STEEL " I " SECTION BEAM/COLUMN	
6	BEADS OF FIREHALT HT ADHESIVE	

**Firehalt**®

Tel : +44 (0)161 344 2484  
 Fax : +44 (0)161 344 2486  
 Email : sales@culimeta-saveguard.com  
 Web : www.firehalt.com

Title:  
 Penetration Management of  
 Steel Beams and Columns

Products:  
 All 30min and  
 15min Insulation  
 Firehalt barriers

Fix Detail: # 22

Version: # 2

Date:  
 30/11/2017

**This fixing detail is for guidance purposes only. If in doubt seek approval from Building Control or another qualified person before installation**