



## TECHNICAL DATASHEET

**Introduction** : **FireHalt 60:30** is a **BRE/LPCB Certified** lightweight symmetrical fire barrier designed to be installed in concealed spaces/roof cavities either as higher specification cavity barrier or as a fire barrier that is required to extend the fire rating of a compartment wall, situated directly below, up to the roof line or upper floor slab.

**Physical Proper-** : Description: No respirable fibres / User friendly / flexible / durable / Easy to manipulate and cut to shape

Colour: White

Coating: Weavelock treatment including a proprietary fire resistant additive which is food safe and non-corrosive.

Minimum Thickness: 7 mm

Minimum Weight: 1900 g/m<sup>2</sup>

Fibre Diameter > 6 micron, (classified non-respirable)

**Certification Body** : **LPCB** **Certified Cavity Barrier** **Ref # 552a/03 (Vertical)**

**Testing Authority** : **Warringtonfire**

**Test & Performance** : **Test Classification** : **BS 476: parts 20/22** **60 mins integrity**  
**30 mins insulation**

**Test Report** : **Ref # 129848** - Expiry date **1st March 2022**

**F O A Reports** : Access Hatch **Ref # 129848\_3**  
- based on the above Horizontal Applications **Ref # 324785\_2**  
test report. Movement joint Applications **Ref # 176621**  
Pipe Protection Applications **Ref # 178495**  
Timber Protection Applications **Ref # 179691**

**Other Classifications** : BS 476 part 6: 1989 Class O (Fire propagation)  
BS 476 part 7: 1987 Class 1 (Surface spread of flame)  
ISO 1182 1990 (E): Non Combustibility  
IMO Resolution MSC.61(67) Part 1. Non Combustibility

**Pack Dimensions** : Width: 130cm | Packed: Convoluted and  
Roll Length: 6m Standard | individually wrapped  
Roll Area: 7.8m<sup>2</sup> | in polythene.



Culimeta-Saveguard Ltd,  
+44 (0)161 344 2484  
sales@firehalt.com  
www.firehalt.com



The information on this Data Sheet is provided in good faith. However, the company reserves the right to alter or update this data as and when additional information is received. Firehalt products should only be fitted in accordance with the guidelines provided by the manufacturer. Any deviations must be authorised by the manufacturer or their representatives.

Issue No:	1	Page:	1 of 1	Dated:	1 March 2019	File Ref:	Prodata firehalt 60_30 v3	.pdf
-----------	---	-------	--------	--------	--------------	-----------	---------------------------	------