



FIRE RESISTANT PARTITION SYSTEM SCHEME

Certificate number: IFCC 1334

Certificate only valid if verified on website – www.ifccertification.com

Issued by IFC Certification Ltd, part of the Kiwa UK Group

This is to certify that

SaveGuard

Tower Mill
Park Road
Dukinfield
SK16 5LP
Tel: 0161 3442484

Who fabricate the following:

Firehalt SF 120 Vertical Fire Barrier System

have satisfied the requirements of the SDP 21 Partitions scheme. This includes the testing of products to **BS476: Part 20/22: 1987** and **BS EN1366-3: 2009**, the inspection of their Factory Production Control continuing surveillance audits and testing of samples of products taken from production. The product specification and field of application to achieve **120 minutes integrity** are detailed on page 2 of this certificate.

Initial Certification: 02 November 2017

Reissued: 01 June 2022

Revised: 31 July 2024

Valid to: 01 November 2027

Issue number: 3

David Mowatt
Head of IFC Certification /
Kiwa Group Limited

*This certificate consists of 2 pages.
Publication of this certificate is permitted.*



The production of fire-resistant partitions are manufactured in accordance with assessment/ test reports and configurations referenced below:

Product Description	Fire Rating	Assessment/Test Report
Firehalt SF 120	120 minutes	PAR/17184/01

Signed on behalf of Kiwa UK

David Mowatt
Head of IFC Certification /
Kiwa Group Limited

The scope of the certification is limited to the details and parameters contained within these reports and all aspects of the specification and limitations defined therein must be satisfied.

It is the certificate holder's responsibility to ensure that the latest version/ revision of the above assessment reports are maintained as part of the audited FPC system.

Failure to comply with all specifications will invalidate the certification and may jeopardise the fire performance.

CERTIFICATE

