

FIRE RESISTANT PARTITION SYSTEM SCHEME

Certificate number: IFCC 1336

Certificate only valid if verified on website – www.ifccertification.com

Issued by IFC Certification Ltd, part of the Kiwa UK Group

This is to certify that

SaveGuard

Corringham Road Ind Estate,
Miller Road
Gainsborough
DN21 1QB
Tel: 01427 810088

Who fabricate the following:

Firehalt Ultralite 60/15 Fire Barrier Systems (Vertical & Horizontal)

have satisfied the requirements of the SDP 21 Fire Rated Partitions scheme v2.1. This includes the testing of products to **BS476: Part 22: 1987**, the inspection of their Factory Production Control continuing surveillance audits and testing of samples of products taken from production. The product specification and field of application to achieve up to **60 minutes integrity and 15 minutes insulation** are detailed on page 2 of this certificate.

Initial Certification: 02 November 2017

Reissued: 23 August 2021

Revised: 23 June 2025


Valid to: 01 November 2027

Issue number: 4

David Mowatt
Head of IFC Certification /
Kiwa Group Limited

*This certificate consists of 2 pages.
Publication of this certificate is permitted.*





The production of fire-resistant partitions are manufactured in accordance with assessment/ test reports and configurations referenced below:

| Product Description | Fire Rating | Assessment/Test Report |
|--|---|------------------------|
| Firehalt Ultralite 60/15 Vertical | 60 minutes integrity 15 minutes insulation | PAR/17184/02 Rev A |
| Firehalt Ultralite 60/15 Horizontal | 60 minutes integrity 15 minutes insulation | PAR/17184/03 Rev A |

Signed on behalf of Kiwa UK

David Mowatt
Head of Certification – IFC Certification /
KIWA Group Limited

The scope of the certification is limited to the details and parameters contained within these reports and all aspects of the specification and limitations defined therein must be satisfied.

It is the certificate holder's responsibility to ensure that the latest version/ revision of the above assessment reports are maintained as part of the audited FPC system.
Failure to comply with all specifications will invalidate the certification and may jeopardise the fire performance.