

# 60:30

## PRODUCT OVERVIEW

Firehalt 60:30 is independently certified by BRE/ LPCB. This multi-layer fire barrier is designed for installation in concealed spaces or roof cavities, serving as either a high-specification cavity barrier or as a fire barrier to extend the fire rating of a compartment wall, situated directly below, up to the roof line or upper floor slab.

### PRODUCT PROPERTIES

Description:	Firehalt 60:30 is a multi-layer fire barrier, that is flexible and durable. Designed for ease of use, the barrier is easy to handle and can be cut to fit any shape
Application:	Vertical use only
Coating:	Weavelock treatment including a proprietary fire-resistant additive which is food safe and non-corrosive
Colour:	White
Minimum Thickness:	7 mm
Minimum Weight:	1900 g/m <sup>2</sup>
Fibre Diameter:	> 6 micron (classified non-respirable)

### TEST & PERFORMANCE

Testing Authority:	Warringtonfire
Test Classification:	BS 476: parts 20/22 - 60 minutes integrity, 30 minutes insulation
Test Report:	Ref # 106946
F O A Reports:	(Based on the above test report) <ul style="list-style-type: none"> <li>• Movement Joint Applications - Ref #176621_3</li> <li>• Timber Protection Applications - Ref #179691_3</li> </ul>
Other Classifications:	<ul style="list-style-type: none"> <li>• BS 476 part 6: 1989 Class 0 (Fire propagation)</li> <li>• BS 476 part 7: 1987 Class 1 (Surface spread of flame)</li> <li>• ISO 1182 1990 (E): Non-Combustibility</li> <li>• IMO Resolution MSC.61(67) Part 1. Non-Combustibility</li> </ul>

### PACKAGING

Pack Dimensions:	Width - 130cm
Roll Length:	6m Standard
Roll Area:	7.8m <sup>2</sup>
Packed:	Convoluted and individually wrapped in polythene

### CERTIFICATION

Certification Body:	BRE/ LPCB
Certified Cavity Barrier:	1872a/01
Certificate available from	RedBook Live

